



OFFICE OF THE ASST. FIRE OFFICER,  
SAMBALPUR F.S


To Whom it may so concern

Certified that on the basis of request, I have checked the Fire Extinguishers of Madnabati Public School At- Ainthapali, Sambalpur on 18/04/2017 and found working condition during verification . Details are as follows; -

- (1) ABC type Fire Extinguisher (cap 10Kg) = 01 no
  - (2) ABC type Fire Extinguisher (cap 06 kg) = 02 no
  - (3) ABC type Fire Extinguisher(cap. 05kg)= 02 no
  - (4) CO2 Fire Extinguisher(cap 4.5 kg)= 03 No
  - (5) Clean Agent (Cap 02 Kg) = 02 nos
- All the extinguishers have been duly refilled on 10.04.2017

Here with it is suggested that, every fire extinguisher must be periodically cleaned, maintained, tested & charged etc as per norms(IS;2190/2010) to upkeep its reliability at all times. Besides working staffs should be given due training on use of fire extinguishers in regular interval under expert hand to deal in case of emergency.


It is pertinent to mention here that a Fire fighting & evacuation mock drill were organized at this school on 18/04/2017 in which all the staffs & students were imparted due training on operational use of Fire Extinguishers.

  
29/6/17  
Asst Fire Officer  
Sambalpur F.S


Memo no. 2624 /SBP FS

Dtd 29/06/2017

Copy submitted to the Principal(I/C), Madnawati Public School, Ainthapali, Sambalpur for favour of information.



**Secretary**  
**Madnawati Public School**  
**Ainthapali, Sambalpur**

  
29/6/17  
Asst Fire Officer  
Sambalpur F.S

